



Certificate of Calibration

Pressure Transmitter Measurement

Certificate No. : 0300-23-HI-CAL-10C

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-23-0008-OTH

Instrument Information

KKS No.	50HBK01CP001	Range	-40 ~ 40
Instrument Description	FURNACE PRESSURE (RIGHT) 1	Unit	mbarg
Manufacture	YOKOGAWA	Out. Signal	4 ~ 20 mA
Model	EJX430A	Max. Error	0.5 %
Serial Number	91VC014378467	Cal. Date	18-05-2023
Instrument Location	Boiler Lt. 9		

Environment Condition

Temperature 27.3 °C
Humidity 49 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbarg]	[mA]	[mA]		[%]		[mbarg]	[mA]	[mA]		[%]	
-40.000	4.020	3.998	-0.022	-0.137	Pass						
-20.000	8.000	7.997	-0.003	-0.019	Pass						
0.000	12.020	12.001	-0.019	-0.119	Pass						
20.000	16.020	16.002	-0.018	-0.113	Pass						
40.000	20.020	20.003	-0.017	-0.106	Pass						
40.000	20.020	20.003	-0.017	-0.106	Pass						
20.000	16.000	15.994	-0.006	-0.038	Pass						
0.000	12.020	12.000	-0.020	-0.125	Pass						
-20.000	8.000	8.015	0.015	0.094	Pass						
-40.000	4.020	3.999	-0.021	-0.131	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR 754	56070038	S. 22 002 081	17-02-2022
PRESSURE MODULE 700 P05	14270508	S. 22 011 744	20-11-2022

Calibration Method

0001/SOP_BJS/2023
Procedure of Calibration Pressure & Differential Transmitter

Customer Signature,

Ayrton Humardani Putradhi

HERVITAMA
Approved Signatory

Arief Cahyadi
INDONESIA

This certificate comprise of 1 page
Date of issue, 19-05-2023

Calibrated by,

Faishol Anwar

PT. HERVITAMA INDONESIA

ELECTRICAL - INSTRUMENTATION - ENGINEERING

Puri Indah DA - 18 Sidoarjo 61224, Telp. (031) 8073636 - 39, Fax: (031) 8074269