



# Certificate of Calibration

## Temperature Sensor Measurement

Certificate No. : 0429-23-HI-CAL-10D

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-23-0009-OTH

### Instrument Information

KKS No.	50HFC10CT003	Range	0 ~ 200
Instrument Description	PULU AOTL TEMP 3	Unit	°C
Manufacture	YAMARI	Out. Signal	-
Model	ENKG TB S	Max. Deviation	1.7 °C (JIS)
Serial Number	5446911	Cal. Date	22-05-2023
Instrument Location	Boiler Lt. 2	Temp. Element	Thermocouple Type E

### Environment Condition

Temperature 27.1 °C  
Humidity 50 % RH

### Calibration Result

Data Reading									
As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	40.00	39.700	-0.300	Pass					
50	49.990	49.900	-0.090	Pass					
100	100.030	100.800	0.770	Pass					
150	150.000	150.800	0.800	Pass					
200	200.010	201.100	1.090	Pass					

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
FIK-754 DOCUMENTING PROCESS CALIBRATOR	3611011	S. 22 011 747	23-11-2022
DRYBLOCK ADDITEL 875	660TH190400016	S-22010642	14-07-2022

### Calibration Method

0002/SOP\_BJS/2023  
Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page  
Date of issue, 23-05-2023

Customer Signature,

Ayrton Humardani Putradhi

HERVITAMA  
Approved Signatory,

INDONESIA

Arief Gunawan

Calibrated by,

Winda Fatikasari

**PT. HERVITAMA INDONESIA**

ELECTRICAL - INSTRUMENTATION - ENGINEERING

Puri Indah DA - 18 Sidoarjo 61224, Telp. (031) 8073636 - 39, Fax: (031) 8074269