



# Certificate of Calibration

## Temperature Sensor Measurement

Certificate No. : 0446-23-HI-CAL-10D

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-23-0008-OTH

### Instrument Information

KKS No.	50HFE11CT001	Range	0 ~ 100
Instrument Description	PRIMARY AIR FAN B INLET AIR TEMPERATURE 1	Unit	°C
Manufacture	YAMARI	Out. Signal	-
Model	P-890904	Max. Deviation	1.7 °C (JIS)
Serial Number	5446816	Cal. Date	14-05-2023
Instrument Location	PA FAN B Boiler Lt.1 Arah Selatan	Temp. Element	Thermocouple Type E

### Environment Condition

Temperature 31,6 °C  
Humidity 61 % RH

### Calibration Result

Data Reading									
As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	40.000	40.100	0.100	Pass					
45	44.990	44.700	-0.290	Pass					
50	50.000	50.100	0.100	Pass					
75	75.000	74.800	-0.200	Pass					
100	100.000	99.600	-0.400	Pass					

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DRYBLOCK ADDITEL 875	660TH210A0009	S-22010643	15-07-2022
Temperature Calibrator Fluke 724	5534569	S. 21 014 752	24-12-2021

### Calibration Method

0002/SOP\_BJS/2023  
Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page  
Date of issue, 15-05-2023

Customer Signature,

Ayrtan Humardani Putradhi

Approved **HERVITAMA**

**INDONESIA**  
Arief Gunawan

Calibrated by,

Winda Fatikasari

**PT. HERVITAMA INDONESIA**

ELECTRICAL - INSTRUMENTATION - ENGINEERING

Puri Indah DA - 18 Sidoarjo 61224, Telp. (031) 8073636 - 39, Fax: (031) 8074269