



# Certificate of Calibration

## Temperature Sensor Measurement

Certificate No. : 0436-23-HI-CAL-10D

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-23-0008-OTH

### Instrument Information

KKS No.	50HLA01CT001	Range	0 ~ 100
Instrument Description	FORCED DRAFT FAN A INLET AIR TEMPERATURE 1	Unit	°C
Manufacture	YAMARI	Out. Signal	-
Model	P-890904	Max. Deviation	1.7 °C (JIS)
Serial Number	5446836	Cal. Date	23-05-2023
Instrument Location	FD FAN A Boiler Lt. 1 Arah Utara	Temp. Element	Thermocouple Type E

### Environment Condition

Temperature 31.3 °C  
Humidity 68 % RH

### Calibration Result

Data Reading									
As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	39.990	39.700	-0.290	Pass					
50	50.000	50.200	0.200	Pass					
60	60.000	60.300	0.300	Pass					
80	80.020	80.600	0.580	Pass					
100	100.010	100.700	0.690	Pass					

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DRYBLOCK ADDITEL 875	660TH210A0009	S-22010643	15-07-2022
FIK-754 DOCUMENTING PROCESS CALIBRATOR	3611011	S. 22 011 747	23-11-2022

### Calibration Method

0002/SOP\_BJS/2023  
Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page  
Date of issue, 24-05-2023

Customer Signature,

Ayrton Humardani Putradhi

Approved Signatory,

Arief Gunawan

Calibrated by,

Khabib Mundzirul Umam

**PT. HERVITAMA INDONESIA**

ELECTRICAL - INSTRUMENTATION - ENGINEERING

Puri Indah DA - 18 Sidoarjo 61224, Telp. (031) 8073636 - 39, Fax: (031) 8074269