



Certificate of Calibration

Pressure Transmitter Measurement

Certificate No. : 0354-23-HI-CAL-10C

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-23-0008-OTH

Instrument Information

KKS No.	50HLA11CP001	Range	-100 ~ 150
Instrument Description	FORCED DRAFT FAN B INLET AIR PRESSURE 1	Unit	mbar
Manufacture	YOKOGAWA	Out. Signal	mA
Model	EJX430A	Max. Error	0.5 %
Serial Number	91UC015098497	Cal. Date	16-05-2023
Instrument Location	FD FAN Boiler Lt. 1		

Environment Condition

Temperature 29.3 °C
Humidity 58 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
-100.000	4.000	4.002	0.002	0.012	Pass						
-37.500	8.000	7.998	-0.002	-0.012	Pass						
25.000	12.000	11.995	-0.005	-0.031	Pass						
87.500	16.000	15.998	-0.002	-0.013	Pass						
150.000	20.000	19.996	-0.004	-0.025	Pass						
150.000	20.000	19.996	-0.004	-0.025	Pass						
87.500	16.000	16.001	0.001	0.006	Pass						
25.000	12.000	11.997	-0.003	-0.019	Pass						
-37.500	8.000	7.999	-0.001	-0.006	Pass						
-100.000	4.000	3.990	-0.010	-0.062	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR 754	56070038	S. 22 002 081	17-02-2022
PRESSURE MODULE 700 P05	14270508	S. 22 011 744	20-11-2022

Calibration Method

0001/SOP_BJS/2023
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
Date of issue, 17-05-2023

Customer Signature,

Ayrton Humardani Putradhi

HERVITAMA
Approved Signatory,

Arief Nurwan

Calibrated by,

Faishol Anwar

PT. HERVITAMA INDONESIA

ELECTRICAL - INSTRUMENTATION - ENGINEERING

Puri Indah DA - 18 Sidoarjo 61224, Telp. (031) 8073636 - 39, Fax: (031) 8074269