



Certificate of Calibration

Pressure Transmitter Measurement

Certificate No. : 0380-23-HI-CAL-10C

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-23-0008-OTH

Instrument Information

KKS No.	50HNC01CP002	Range	0 ~ 100
Instrument Description	INDUCED DRAFT FAN A CONTROL OIL PRESSURE 2	Unit	barg
Manufacture	YOKOGAWA	Out. Signal	4 ~ 20 mA
Model	EJX430A	Max. Error	0.5 %
Serial Number	91UC015348507	Cal. Date	21-05-2023
Instrument Location	ID FAN A		

Environment Condition

Temperature 30 °C
 Humidity 62 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
0.000	4.000	4.001	0.001	0.006	Pass						
25.010	8.004	8.004	0.000	0.000	Pass						
49.990	11.998	11.998	0.000	0.000	Pass						
75.010	16.001	16.000	-0.001	-0.006	Pass						
100.040	20.006	20.005	-0.001	-0.006	Pass						
100.040	20.006	20.005	-0.001	-0.006	Pass						
75.010	16.001	16.002	0.001	0.006	Pass						
49.990	11.998	11.999	0.001	0.006	Pass						
25.010	8.004	8.003	-0.001	-0.006	Pass						
0.000	4.000	4.003	0.003	0.019	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR 754	43550006	S. 22 002 080	21-02-2022
PRESSURE MODULE P31	4472839	S. 23 004 595	27-03-2023

Calibration Method

0001/SOP_BJS/2023
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
 Date of issue, 22-05-2023

Customer Signature,

Ayrton Humardani Putradhi

Approved Signatory

Arief Gunawan
 PT. HERVITAMA INDONESIA

Calibrated by,

Ryan Franki Risdianto

PT. HERVITAMA INDONESIA

ELECTRICAL - INSTRUMENTATION - ENGINEERING

Puri Indah DA - 18 Sidoarjo 61224, Telp. (031) 8073636 - 39, Fax: (031) 8074269