



Certificate of Calibration

Pressure Transmitter Measurement

Certificate No. : 0399-23-HI-CAL-10C

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-23-0008-OTH

Instrument Information

KKS No.	50HNC11CP008	Range	0 ~ 100
Instrument Description	INDUCED DRAFT FAN B SEAL AIR PRESSURE 2	Unit	mbarg
Manufacture	YOKOGAWA	Out. Signal	4 ~ 20 mA
Model	EJX430A	Max. Error	0.5 %
Serial Number	91UC015578507	Cal. Date	22-05-2023
Instrument Location	ID FAN B Lt. 1		

Environment Condition

Temperature 29.2 °C
 Humidity 50 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbarg]	[mA]	[mA]		[%]		[mbarg]	[mA]	[mA]		[%]	
0.000	4.016	4.001	-0.015	-0.094	Pass						
25.000	8.000	8.007	0.007	0.044	Pass						
50.000	12.000	12.006	0.006	0.038	Pass						
75.000	16.000	16.006	0.006	0.038	Pass						
100.000	20.000	20.000	0.000	0.000	Pass						
100.000	20.000	20.000	0.000	0.000	Pass						
75.000	16.000	16.006	0.006	0.038	Pass						
50.000	12.000	12.006	0.006	0.038	Pass						
25.000	8.000	8.006	0.006	0.038	Pass						
0.000	4.016	4.006	-0.010	-0.062	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR 754	56070038	S. 22 002 081	17-02-2022
PRESSURE MODULE 700 P05	14270508	S. 22 011 744	20-11-2022

Calibration Method

0001/SOP_BJS/2023
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
 Date of issue, 23-05-2023

Customer Signature,

Ayrton Humardani Putradhi

HERVITAMA
 Approved Signatory,

INDONESIA
 Arief Gundawan

Calibrated by,

Faishol Anwar

PT. HERVITAMA INDONESIA

ELECTRICAL - INSTRUMENTATION - ENGINEERING

Puri Indah DA - 18 Sidoarjo 61224, Telp. (031) 8073636 - 39, Fax: (031) 8074269