



Certificate of Calibration

Temperature Sensor Measurement

Certificate No. : 0148-23-HI-CAL-10D

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-23-0008-OTH

Instrument Information

KKS No.	50LAB09CT015	Range	0 ~ 300
Instrument Description	HP HEATER 7B OUTLET WATER TEMPERATURE	Unit	°C
Manufacture	YAMARI SANGYO	Out. Signal	-
Model	T/C, TERMINAL HEAD TYPE(TYPE-E : Double Element)	Max. Deviation	3 °C
Serial Number	5263795	Cal. Date	17-05-2023
Instrument Location	Turbin Lt. 3	Temp. Element	Thermocouple Type E

Environment Condition

Temperature 28.1 °C
Humidity 58 % RH

Calibration Result

Data Reading									
As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	40.040	40.300	0.260	Pass					
120	120.070	121.900	1.830	Pass					
180	180.000	182.000	2.000	Pass					
240	240.030	242.600	2.570	Pass					
300	300.090	302.000	1.910	Pass					

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DRYBLOCK ADDITEL 875	660TH210A0009	S-22010643	15-07-2022
Temperature Calibrator Fluke 724	5534569	S. 21 014 752	24-12-2021

Calibration Method

0002/SOP_BJS/2023
Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page
Date of issue, 18-05-2023

Customer Signature,

Ayrton Humardani Putradhi

Approved Signatory,

Andri Gultawan

Calibrated by,

Winda Fatikasari