



Certificate of Calibration

Level Transmitter Measurement

Certificate No. : 0109-23-HI-CAL-101

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-23-0008-OTH

Instrument Information

KKS No.	50LAD12CL010	Range	NWL-250 ~ NWL+660
Instrument Description	HP HEATER 6B LEVEL 2	Unit	mm
Manufacture	YOKOGAWA	Out. Signal	4 ~ 20 mA
Model	EJX118A-JMSCC-917DB- WA23B2SW00-AA2A/D3/C1/A1	Max. Error	0.5 %
Serial Number	91V301552	Cal. Date	29-05-2023
Instrument Location	Turbin Lt. 3		

Environment Condition

Temperature 28 °C
 Humidity 70 % RH

Calibration Result

Data Reading (Transmitter)																
As Found								As Left								
Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Std Output	Output UUT	Deviation	Error	Result	
[mm]	[mm]	[mm]	[mA]	[mA]		[%]		[mm]	[mm]	[mm]	[mA]	[mA]		[%]		
-250	-250	-254.2	4.000	3.982	-0.018	-0.112	Pass									
-22.5	-22.5	22.0	8.000	7.970	-0.030	-0.188	Pass									
205	205	200.8	12.000	11.980	-0.020	-0.125	Pass									
432.5	432.5	427.5	16.000	15.962	-0.038	-0.237	Pass									
660	660	661.3	20.000	20.019	0.019	0.119	Pass									
NWL	0	0.53		8.303												

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Roll Meter	L04220787	009/L2/H1/2020	21-04-2022
STEEL RULER 017/L3/HI/2020	-	S. 23 004 597	24-03-2023

Calibration Method

0009/SOP_BJS/2023
 Procedure of Calibration Level Transmitter

This certificate comprise of 1 page
 Date of issue, 30-05-2023

Customer Signature,

Ayrtan Humardani Putradhi

Approved Signature,



INDONESIA
Arief Gunawan

Calibrated by,

R. Heru Setyo Utomo

PT. HERVITAMA INDONESIA

ELECTRICAL - INSTRUMENTATION - ENGINEERING

Puri Indah DA - 18 Sidoarjo 61224, Telp. (031) 8073636 - 39, Fax: (031) 8074269