



# Certificate of Calibration

## Pressure Switch Measurement

Certificate No. : 0055-23-HI-CAL-10B

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-23-0008-OTH

### Instrument Information

KKS No.	50LAV31CP305	Range	0.2 - 2
Instrument Description	BFPT A LUBE OIL PRESSURE LOW 1	Set	0.281
Manufacture	NAGANO KEIKI	Reset	0.486
Model	CB33-2X3	Unit	barg
Serial Number	W11828	MPE	± 0.01
Instrument Location	Turbin Lt. 1	Cal. Date	25-05-2023

### Environment Condition

Temperature 27.2 °C  
Humidity 57 % RH

### Calibration Result

Data Reading (Switch)					
As Found			As Left		
Set	Reset	Deadband	Set	Reset	Deadband
0.283	0.504	0.221			
0.283	0.500	0.217			
0.284	0.500	0.216			

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR 754	56070038	S. 22 002 081	17-02-2022
PRESSURE MODULE 700 P05	14270508	S. 22 011 744	20-11-2022

### Calibration Method

0003/SOP\_BJS/2023  
Procedure of Calibration Pressure Switch

This certificate comprise of 1 page  
Date of issue, 26-05-2023

Customer Signature,

Ayrton Humardani Putradhi

Approved Signatory,

Arief Gunawan

Calibrated by,

Faishol Anwar

**PT. HERVITAMA INDONESIA**

ELECTRICAL - INSTRUMENTATION - ENGINEERING

Puri Indah DA - 18 Sidoarjo 61224, Telp. (031) 8073636 - 39, Fax: (031) 8074269