



# Certificate of Calibration

## Pressure Switch Measurement

Certificate No. : 0063-23-HI-CAL-10B

### Customer Information

Company Name PT. Bumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-23-0008-OTH

### Instrument Information

KKS No.	50LAX11CP315	Range	2 - 20
Instrument Description	BFPT A EHC OIL PRESSURE LOW	Set	7.9
Manufacture	NAGANO KEIKI	Reset	8.9
Model	CB33-2X3	Unit	barg
Serial Number	W11834	MPE	± 0.09
Instrument Location	Turbin Lt. 1	Cal. Date	17-05-2023

### Environment Condition

Temperature 29 °C  
Humidity 62 % RH

### Calibration Result

Data Reading (Switch)					
As Found			As Left		
Set	Reset	Deadband	Set	Reset	Deadband
7.970	8.871	0.901			
7.970	8.871	0.901			
7.970	8.871	0.901			

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR 754	43550006	S. 22 002 080	21-02-2022
PRESSURE MODULE 700P08	14070813	S. 23 004 594	27-03-2023

### Calibration Method

0003/SOP\_BJS/2023  
Procedure of Calibration Pressure Switch

This certificate comprise of 1 page  
Date of issue, 18-05-2023

Customer Signature,

Ayrton Humardani Putradhi

Approved Signatory,

**INDONESIA**  
Arief Gunawan

Calibrated by,

Ryan Franki Risdianto

**PT. HERVITAMA INDONESIA**

ELECTRICAL - INSTRUMENTATION - ENGINEERING

Puri Indah DA - 18 Sidoarjo 61224, Telp. (031) 8073636 - 39, Fax: (031) 8074269