



Certificate of Calibration

Pressure Switch Measurement

Certificate No. : 0064-23-HI-CAL-10B

Customer Information

Company Name
Address
Contract No.

PT. Bhumi Jati Power
PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
C-BJP-23-0008-OTH

Instrument Information

KKS No.
Instrument Description
Manufacture
Model
Serial Number
Instrument Location

50LAX11CP320
BFPT A EMERGENCY OIL PRESSURE LOW 1
NAGANO KEIKI
CB33-2X3
W11836
Turbin Lt. 1

Range 2 - 20
Set 5
Reset 6.8
Unit barg
MPE ± 0.09
Cal. Date 17-05-2023

Environment Condition

Temperature
Humidity

29 °C
65 % RH

Calibration Result

Data Reading (Switch)					
As Found			As Left		
Set	Reset	Deadband	Set	Reset	Deadband
5.102	6.660	1.558	5.033	6.722	1.689
5.102	6.660	1.558	5.033	6.722	1.689
5.102	6.660	1.558	5.033	6.722	1.689

Standard Reference

Description
DOCUMENTING PROCESS
CALIBRATOR 754
PRESSURE MODULE
700P08

Serial Number
43550006
14070813

Certificate Number
S. 22 002 080
S. 23 004 594

Calibration Date
21-02-2022
27-03-2023

Calibration Method

0003/SOP_BJS/2023
Procedure of Calibration Pressure Switch

This certificate comprise of 1 page
Date of issue, 18-05-2023

Customer Signature,

Ayrton Humardani Putradhi

Approved Signatory,

INDONESIA
Arief Gunawan

Calibrated by,

Ryan Franki Risdianto

PT. HERVITAMA INDONESIA

ELECTRICAL - INSTRUMENTATION - ENGINEERING

Puri Indah DA - 18 Sidoarjo 61224, Telp. (031) 8073636 - 39, Fax: (031) 8074269