



Certificate of Calibration

Temperature Sensor Measurement

Certificate No. : 0152-23-HI-CAL-10D

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-23-0008-OTH

Instrument Information

KKS No.	50LBA15CT005	Range	0 - 700
Instrument Description	MAIN STEAM A TEMPERATURE	Unit	°C
Manufacture	YAMARI SANGYO	Out. Signal	-
Model	T/C, TERMINAL HEAD TYPE(TYPE-K:Double Element)	Max. Deviation	7 °C
Serial Number	-	Cal. Date	30-05-2023
Instrument Location	Turbin Lt. 2	Temp. Element	Thermocouple Type K

Environment Condition

Temperature 29.8 °C
Humidity 45 % RH

Calibration Result

Data Reading									
As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	40.000	39.700	-0.300	Pass					
175	175.000	174.700	-0.300	Pass					
350	350.000	349.700	-0.300	Pass					
525	525.000	524.700	-0.300	Pass					
700	700.000	699.700	-0.300	Pass					

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Temperature Calibrator Fluke 724	5534569	S. 23 004 603	17-04-2023

Calibration Method

0002/SOP_BJS/2023
Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page

Date of issue, 31-05-2023

Customer Signature,

Ayrton Humardani Putradhi

Approved by,

Arief Gunawan

Calibrated by,

Khabib Mundzirul Umam

PT. HERVITAMA INDONESIA

ELECTRICAL - INSTRUMENTATION - ENGINEERING

Puri Indah DA - 18 Sidoarjo 61224, Telp. (031) 8073636 - 39, Fax: (031) 8074269