



Certificate of Calibration

Temperature Sensor Measurement

Certificate No. : 0157-23-HI-CAL-10D

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-23-0008-OTH

Instrument Information

KKS No.	50LBQ30CT005	Range	0 ~ 600
Instrument Description	NO.6 EXTRACTION STEAM DESUPERHEATER STEAM TEMPERATURE	Unit	°C
Manufacture	YAMARI SANGYO	Out. Signal	-
Model	T/C, TERMINAL HEAD TYPE(TYPE- E:Double Element)	Max. Deviation	6 °C
Serial Number	5263804	Cal. Date	27-05-2023
Instrument Location	Turbin Lt. 3	Temp. Element	Thermocouple Type E

Environment Condition

Temperature 26.1 °C
Humidity 48 % RH

Calibration Result

Data Reading									
As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	40.000	40.500	0.500	Pass					
150	149.990	150.500	0.510	Pass					
300	300.000	300.400	0.400	Pass					
450	450.000	450.000	0.000	Pass					
600	600.000	600.100	0.100	Pass					

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DRYBLOCK ADDITEL 875	660TH190400016	S-22010642	14-07-2022
FIK-754 DOCUMENTING PROCESS CALIBRATOR	3611011	S. 22 011 747	23-11-2022

Calibration Method

0002/SOP_BJS/2023
Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page
Date of issue, 28-05-2023

Customer Signature,

Approved Signature, MA

Calibrated by,

INDONESIA
Arief Gunawan

Winda Fatikasari