



Certificate of Calibration

Pressure Transmitter Measurement

Certificate No. : 0025-23-HI-CAL-10C

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-23-0008-OTH

Instrument Information

KKS No. 50LBQ31CP005 Range -0.785 ~ 30.215
Instrument Description HP HEATER 6A EXTRACTION STEAM PRESSURE Unit barg
Manufacture YOKOGAWA Out. Signal 4 ~ 20 mA
Model EJX430A-JAS4C-717DD/D3/C1 Max. Error 0.5 %
Serial Number 91V1046649037 Cal. Date 16-05-2023
Instrument Location Turbin Lt. 3

Environment Condition

Temperature 29 °C
Humidity 67 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
-0.786	3.999	3.999	0.000	0.000	Pass						
6.964	7.999	8.001	0.002	0.012	Pass						
14.713	11.999	12.001	0.002	0.012	Pass						
22.463	15.999	16.002	0.003	0.019	Pass						
30.213	19.999	20.001	0.002	0.013	Pass						
30.213	19.999	20.001	0.002	0.013	Pass						
22.463	15.999	16.003	0.004	0.025	Pass						
14.713	11.999	12.001	0.002	0.012	Pass						
6.964	7.999	8.001	0.002	0.012	Pass						
-0.786	3.999	4.001	0.002	0.013	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR 754	43550006	S. 22 002 080	21-02-2022
PRESSURE MODULE 700P08	14070813	S. 23 004 594	27-03-2023

Calibration Method

0001/SOP_BJS/2023
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
Date of issue, 17-05-2023

Customer Signature,

Ayrton Humardani Putradhi

HERVITAMA
Approved Signatory,

Arief INDONESIA

Calibrated by,

Ryan Franki Risdianto

PT. HERVITAMA INDONESIA

ELECTRICAL - INSTRUMENTATION - ENGINEERING

Puri Indah DA - 18 Sidoarjo 61224, Telp. (031) 8073636 - 39, Fax: (031) 8074269