



# Certificate of Calibration

## Pressure Switch Measurement

Certificate No. : 0073-23-HI-CAL-10B

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-23-0008-OTH

### Instrument Information

KKS No.	50LBR11CP305	Range	-1 - 0
Instrument Description	BFPT A EXHAUST STEAM PRESSURE HIGH	Set	-0.831
Manufacture	NAGANO KEIKI	Reset	-0.858
Model	CB33-2X3	Unit	barg
Serial Number	W12633	MPE	± 0.005
Instrument Location	Turbin Lt. 2	Cal. Date	29-05-2023

### Environment Condition

Temperature 27.1 °C  
Humidity 55 % RH

### Calibration Result

Data Reading (Switch)					
As Found			As Left		
Set	Reset	Deadband	Set	Reset	Deadband
-0.827	-0.855	0.028			
-0.827	-0.856	0.029			
-0.827	-0.856	0.029			

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR 754	56070038	S. 22 002 081	17-02-2022
Pressure Module Fluke 750PD4	4474073	S. 21 011 085	07-10-2021

### Calibration Method

0003/SOP\_BJS/2023  
Procedure of Calibration Pressure Switch

This certificate comprise of 1 page  
Date of issue, 30-05-2023

Customer Signature,

Ayrton Humardani Putradhi

Approved Signatory,



Arief Gunawan

Calibrated by,

Faishol Anwar

**PT. HERVITAMA INDONESIA**

ELECTRICAL - INSTRUMENTATION - ENGINEERING

Puri Indah DA - 18 Sidoarjo 61224, Telp. (031) 8073636 - 39, Fax: (031) 8074269