



Certificate of Calibration

Pressure Switch Measurement

Certificate No. : 0074-23-HI-CAL-10B

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-23-0008-OTH

Instrument Information

KKS No.	50LBR12CP305	Range	-1 - 0
Instrument Description	BFPT B EXHAUST STEAM PRESSURE HIGH	Set	-0.835
Manufacture	NAGANO KEIKI	Reset	-0.863
Model	CB33-2X3	Unit	barg
Serial Number	W12634	MPE	± 0.005
Instrument Location	Turbin Lt. 2	Cal. Date	29-05-2023

Environment Condition

Temperature 27.1 °C
Humidity 55 % RH

Calibration Result

Data Reading (Switch)					
As Found			As Left		
Set	Reset	Deadband	Set	Reset	Deadband
-0.829	-0.866	0.037			
-0.829	-0.858	0.029			
-0.829	-0.858	0.029			

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR 754	56070038	S. 22 002 081	17-02-2022
Pressure Module Fluke 750PD4	4474073	S. 21 011 085	07-10-2021

Calibration Method

0003/SOP_BJS/2023
Procedure of Calibration Pressure Switch

This certificate comprise of 1 page
Date of issue, 30-05-2023

Customer Signature,

Ayrton Humardani Putradhi

Approved Signatory,



Arief Gunawan

Calibrated by,

Faishol Anwar

PT. HERVITAMA INDONESIA

ELECTRICAL - INSTRUMENTATION - ENGINEERING

Puri Indah DA - 18 Sidoarjo 61224, Telp. (031) 8073636 - 39, Fax: (031) 8074269