



Certificate of Calibration

Temperature Sensor Measurement

Certificate No. : 0168-23-HI-CAL-10D

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-23-0008-OTH

Instrument Information

KKS No.	50LCA70CT005	Range	0 ~ 200
Instrument Description	LP HEATER 4 OUTLET WATER TEMPERATURE	Unit	°C
Manufacture	YAMARI SANGYO	Out. Signal	-
Model	T/C, TERMINAL HEAD TYPE(TYPE-E : Double Element)	Max. Deviation	1.7 °C (JIS)
Serial Number	5263816E	Cal. Date	25-05-2023
Instrument Location	Turbin Lt. 3	Temp. Element	Thermocouple Type E

Environment Condition

Temperature 26.5 °C
Humidity 50 % RH

Calibration Result

Data Reading									
As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	40.000	39.600	-0.400	Pass					
50	49.990	49.500	-0.490	Pass					
100	100.000	99.500	-0.500	Pass					
150	150.010	149.500	-0.510	Pass					
200	200.000	200.600	0.600	Pass					

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DRYBLOCK ADDITEL 875	660TH190400016	S-22010642	14-07-2022
FIK-754 DOCUMENTING PROCESS CALIBRATOR	3611011	S. 22 011 747	23-11-2022

Calibration Method

0002/SOP_BJS/2023
Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page
Date of issue, 26-05-2023

Customer Signature,

Ayrton Humardani Putradhi

Approved Signatory

Arief Gunawan

Calibrated by,

Khabib Mundzirul Umam

PT. HERVITAMA INDONESIA

ELECTRICAL - INSTRUMENTATION - ENGINEERING

Puri Indah DA - 18 Sidoarjo 61224, Telp. (031) 8073636 - 39, Fax: (031) 8074269