



Certificate of Calibration

Temperature Sensor Measurement

Certificate No. : 0170-23-HI-CAL-10D

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-23-0008-OTH

Instrument Information

KKS No. 50LCH10CT005 Range 0 ~ 350
Instrument Description HP HEATER 8A DRAIN TEMPERATURE Unit °C
Manufacture YAMARI SANGYO Out. Signal -
Model T/C, TERMINAL HEAD TYPE(TYPE-E:Double Element) Max. Deviation 3.5 °C
Serial Number 5263818 Cal. Date 26-05-2023
Instrument Location Turbin Lt. 4 Temp. Element Thermocouple Type E

Environment Condition

Temperature 22.7 °C
Humidity 56 % RH

Calibration Result

Data Reading									
As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	40.000	40.100	0.100	Pass					
87.5	87.500	87.800	0.300	Pass					
175	175.000	175.700	0.700	Pass					
262.5	262.500	263.500	1.000	Pass					
350	350.000	352.200	2.200	Pass					

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DRYBLOCK ADDITEL 875	660TH210A0009	S-22010643	15-07-2022
FIK-754 DOCUMENTING PROCESS CALIBRATOR	3611011	S. 22 011 747	23-11-2022

Calibration Method

0002/SOP_BJS/2023
Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page
Date of issue, 27-05-2023

Customer Signature,

Ayrton Humardani Putradhi

Approved Signatory

Arief Gunawan

Calibrated by,

Winda Fatikasari

PT. HERVITAMA INDONESIA

ELECTRICAL - INSTRUMENTATION - ENGINEERING

Puri Indah DA - 18 Sidoarjo 61224, Telp. (031) 8073636 - 39, Fax: (031) 8074269