



Certificate of Calibration

Temperature Sensor Measurement

Certificate No. : 0174-23-HI-CAL-10D

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-23-0008-OTH

Instrument Information

KKS No.	50LCH30CT005	Range	0 ~ 250
Instrument Description	HP HEATER 6A DRAIN TEMPERATURE	Unit	°C
Manufacture	YAMARI SANGYO	Out. Signal	-
Model	T/C, TERMINAL HEAD TYPE(TYPE-E : Double Element)	Max. Deviation	2.5 °C
Serial Number	5263820	Cal. Date	25-05-2023
Instrument Location	Turbin Lt. 3	Temp. Element	Thermocouple Type E

Environment Condition

Temperature 27.8 °C
Humidity 55 % RH

Calibration Result

Data Reading									
As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	40.000	40.200	0.200	Pass					
62.5	62.500	62.900	0.400	Pass					
125	125.020	126.000	0.980	Pass					
187.5	187.500	188.600	1.100	Pass					
250	250.020	250.800	0.780	Pass					

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DRYBLOCK ADDITEL 875	660TH190400016	S-22010642	14-07-2022
FIK-754 DOCUMENTING PROCESS CALIBRATOR	3611011	S. 22 011 747	23-11-2022

Calibration Method

0002/SOP_BJS/2023
Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page
Date of issue, 26-05-2023

Customer Signature,

Ayrton Humardani Putradhi

Approved Signature

Arief Gunawan

Calibrated by,

Winda Fatikasari

PT. HERVITAMA INDONESIA

ELECTRICAL - INSTRUMENTATION - ENGINEERING

Puri Indah DA - 18 Sidoarjo 61224, Telp. (031) 8073636 - 39, Fax: (031) 8074269