



# Certificate of Calibration

## Temperature Sensor Measurement

Certificate No. : 0175-23-HI-CAL-10D

### Customer Information

Company Name PT. Bhumi Jati Power  
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No. C-BJP-23-0008-OTH

### Instrument Information

KKS No.	50LCH31CT005	Range	0 ~ 250
Instrument Description	HP HEATER 6B DRAIN TEMPERATURE	Unit	°C
Manufacture	YAMARI SANGYO	Out. Signal	-
Model	T/C, TERMINAL HEAD TYPE(TYPE-E : Double Element)	Max. Deviation	2.5 °C
Serial Number	5263821	Cal. Date	25-05-2023
Instrument Location	Turbin Lt. 3	Temp. Element	Thermocouple Type E

### Environment Condition

Temperature 26.5 °C  
 Humidity 51 % RH

### Calibration Result

Data Reading									
As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	40.000	39.800	-0.200	Pass					
62.5	62.490	62.300	-0.190	Pass					
125	125.000	124.900	-0.100	Pass					
187.5	187.510	187.500	-0.010	Pass					
250	250.010	251.100	1.090	Pass					

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DRYBLOCK ADDITEL 875	660TH210A0009	S-22010643	15-07-2022
FIK-754 DOCUMENTING PROCESS CALIBRATOR	3611011	S. 22 011 747	23-11-2022

### Calibration Method

0002/SOP\_BJS/2023  
 Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page  
 Date of issue, 26-05-2023

Customer Signature,

Ayrton Humardani Putradhi

Approved Signature,

Arief Gunawan

Calibrated by,

Winda Fatikasari

**PT. HERVITAMA INDONESIA**

ELECTRICAL - INSTRUMENTATION - ENGINEERING

Puri Indah DA - 18 Sidoarjo 61224, Telp. (031) 8073636 - 39, Fax: (031) 8074269