



Report of Inspection

Vibration Sensor

Report No. : 0271-23-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-23-0008-OTH

Instrument Information

KKS No. 50MAA10CY001
Instrument Description HPT DIFFERENTIAL EXPANSION
Manufacture SHINKAWA
Model FL-263F50L-M1-00-05-10
Serial Number T9SN0055
Instrument Location Turbin Lt. 3

Inspection Date 19-05-2023

Environment Condition

Temperature 31 °C
Humidity 61 % RH

Inspection Result

Visual Inspection

Cabel Tightness	✓	OK
Cable Condition	✓	OK
Mounting	✓	OK
Phisical Condition	✓	OK

	Not OK
	Not OK
	Not OK
	Not OK

Healthiness

Good

Measurement

V - Supply	- 25.43
V - Out	- 08.08
Resistance [Ω]	5.5

Remark

Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
TRUE RMS MULTIMETER	160403244	S. 21 011 088	05-10-2021

Inspection Method

0006/SOP_BJS/2023
Procedure of Inspection Vibration

This certificate comprise of 1 page
Date of issue, 20-05-2023

Customer Signature,

Ayrton Humardani Putradhi

HERVITAMA
Approved Signatory,



INDONESIA
Ariel Gunawan

Calibrated by,

Abdul Latif

PT. HERVITAMA INDONESIA

ELECTRICAL - INSTRUMENTATION - ENGINEERING

Puri Indah DA - 18 Sidoarjo 61224, Telp. (031) 8073636 - 39, Fax: (031) 8074269