



# Certificate of Calibration

## Level Switch Measurement

Certificate No. : 0133-23-HI-CAL-101

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-23-0008-OTH

### Instrument Information

KKS No. 50MAG16CL305  
Instrument Description CONDENSER WATER BOX B LEVEL HIGH  
Manufacture NAKAKITA  
Model NS-287-71-A1F3-10L0G-F  
Serial Number 19H6006  
Instrument Location Turbin Lt. 1

Type of Testing Function Test  
Cal. Date 03-06-2023

### Environment Condition

Temperature 31.1 °C  
Humidity 70 % RH

### Calibration Result

Data Reading (Switch)			
As Found		As Left	
Open to Close	Close to Open	Open to Close	Close to Open
OK	OK		
OK	OK		

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
ROLL METER	-	L04220787	26-04-2022
STEEL RULER 018/L3/HI/2020	-	S. 23 004 598	24-03-2023

### Calibration Method

0008/SOP\_BJS/2023  
Procedure of Calibration Level Switch

This certificate comprise of 1 page  
Date of issue, 04-06-2023

Customer Signature,

Ayrtan Humardani Putradhi

Approved Signatory

Arief Gunawan

Calibrated by,

R. Heru Setyo Utomo

PT. HERVITAMA INDONESIA

ELECTRICAL - INSTRUMENTATION - ENGINEERING

Puri Indah DA - 18 Sidoarjo 61224, Telp. (031) 8073636 - 39, Fax: (031) 8074269