



Certificate of Calibration

Pressure Switch Measurement

Certificate No. : 0075-23-HI-CAL-10B

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-23-0008-OTH

Instrument Information

KKS No.	50MAV10CP305	Range	1 - 10
Instrument Description	LUBE OIL PRESSURE LOW (EMERGENCY OIL PUMP START)	Set	2.82
Manufacture	NAGANO KEIKI	Reset	3.13
Model	CB33-2X3	Unit	barg
Serial Number	W11505	MPE	± 0.045
Instrument Location	Turbin Lt. 2	Cal. Date	26-05-2023

Environment Condition

Temperature 29 °C
Humidity 63 % RH

Calibration Result

Data Reading (Switch)					
As Found			As Left		
Set	Reset	Deadband	Set	Reset	Deadband
2.834	3.110	0.276			
2.827	3.110	0.283			
2.827	3.110	0.283			

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR 754	43550006	S. 22 002 080	21-02-2022
PRESSURE MODULE 700P08	14070813	S. 23 004 594	27-03-2023

Calibration Method

0003/SOP_BJS/2023
Procedure of Calibration Pressure Switch

This certificate comprise of 1 page
Date of issue, 27-05-2023

Customer Signature,

Ayrton Humardani Putradhi

Approved Signatory,

Arief Gurawan

Calibrated by,

Ryan Franki Risdianto

PT. HERVITAMA INDONESIA

ELECTRICAL - INSTRUMENTATION - ENGINEERING

Puri Indah DA - 18 Sidoarjo 61224, Telp. (031) 8073635 - 39, Fax: (031) 8074269