



Certificate of Calibration

Pressure Switch Measurement

Certificate No. : 0077-23-HI-CAL-10B

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-23-0008-OTH

Instrument Information

KKS No.	50MAV52CP305	Range	0.6 - 6
Instrument Description	TURNING GEAR INTERLOCK PRESSURE HIGH	Set	1.79
Manufacture	NAGANO KEIKI	Reset	1.6
Model	CB33-2X3	Unit	barg
Serial Number	W12638	MPE	± 0.027
Instrument Location	Turbin Lt. 2	Cal. Date	29-05-2023

Environment Condition

Temperature 27.2 °C
Humidity 55 % RH

Calibration Result

Data Reading (Switch)					
As Found			As Left		
Set	Reset	Deadband	Set	Reset	Deadband
1.788	1.601	0.187			
1.790	1.600	0.190			
1.790	1.600	0.190			

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR 754	56070038	S. 22 002 081	17-02-2022
PRESSURE MODULE 700 P05	14270508	S. 22 011 744	20-11-2022

Calibration Method

0003/SOP_BJS/2023
Procedure of Calibration Pressure Switch

This certificate comprise of 1 page
Date of issue, 30-05-2023

Customer Signature,

Ayrton Humardani Putradhi

Approved by,

Arief Gunawan

Calibrated by,

Faishol Anwar

PT. HERVITAMA INDONESIA

ELECTRICAL - INSTRUMENTATION - ENGINEERING

Puri Indah DA - 18 Sidoarjo 61224, Telp. (031) 8073636 - 39, Fax: (031) 8074269