



Certificate of Calibration

Pressure Switch Measurement

Certificate No. : 0078-23-HI-CAL-10B

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-23-0008-OTH

Instrument Information

| | | | |
|------------------------|-------------------------------------|-----------|------------|
| KKS No. | 50MAV60CP305 | Range | 600 - 6000 |
| Instrument Description | TURBINE LUBE OIL PRESSURE LOW LOW 3 | Set | 1380 |
| Manufacture | NAGANO KEIKI | Reset | 1750 |
| Model | CB33-2X3 | Unit | mbar |
| Serial Number | W12637 | MPE | ± 30 |
| Instrument Location | Turbin Lt. 2 | Cal. Date | 27-05-2023 |

Environment Condition

Temperature 30 °C
Humidity 72 % RH

Calibration Result

| Data Reading (Switch) | | | | | |
|-----------------------|----------|----------|---------|-------|----------|
| As Found | | | As Left | | |
| Set | Reset | Deadband | Set | Reset | Deadband |
| 1383.000 | 1757.500 | 374.500 | | | |
| 1382.500 | 1763.700 | 381.200 | | | |
| 1381.900 | 1802.400 | 420.500 | | | |

Standard Reference

| Description | Serial Number | Certificate Number | Calibration Date |
|------------------------------------|---------------|--------------------|------------------|
| DOCUMENTING PROCESS CALIBRATOR 754 | 56070038 | S. 22 002 081 | 17-02-2022 |
| PRESSURE MODULE 700 P05 | 14270508 | S. 22 011 744 | 20-11-2022 |

Calibration Method

0003/SOP_BJS/2023
Procedure of Calibration Pressure Switch

This certificate comprise of 1 page
Date of issue, 28-05-2023

Customer Signature,

Ayrton Humardani Putradhi

Approved by,

INDONESIA
Arief Gunawan

Calibrated by,

Faishol Anwar

PT. HERVITAMA INDONESIA

ELECTRICAL - INSTRUMENTATION - ENGINEERING

Puri Indah DA - 18 Sidoarjo 61224, Telp. (031) 8073636 - 39, Fax: (031) 8074269