



Certificate of Calibration

Pressure Switch Measurement

Certificate No. : 0081-23-HI-CAL-10B

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-23-0008-OTH

Instrument Information

KKS No.	50MAX30CP302	Range	15 - 150
Instrument Description	EHC OIL PRESSURE LOW LOW 1	Set	114
Manufacture	NAGANO KEIKI	Reset	120
Model	CB33-2X3	Unit	barg
Serial Number	W1748	MPE	± 0.675
Instrument Location	Turbin Lt. 1	Cal. Date	18-05-2023

Environment Condition

Temperature 29 °C
Humidity 65 % RH

Calibration Result

Data Reading (Switch)					
As Found			As Left		
Set	Reset	Deadband	Set	Reset	Deadband
112.250	118.520	6.270	113.970	119.900	5.930
112.250	118.520	6.270	113.970	119.900	5.930
112.250	118.520	6.270	113.970	119.900	5.930

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR 754	43550006	S. 22 002 080	21-02-2022
PRESSURE MODULE P31	4472839	S. 23 004 595	27-03-2023

Calibration Method

0003/SOP_BJS/2023
Procedure of Calibration Pressure Switch

This certificate comprise of 1 page
Date of issue, 19-05-2023

Customer Signature,

Ayrton Humardani Putradhi

Approved by, **HERVITAMA**

Arief Gunawan

Calibrated by,

Ryan Franki Risdianto

PT. HERVITAMA INDONESIA
ELECTRICAL - INSTRUMENTATION - ENGINEERING

Puri Indah DA - 18 Sidoarjo 61224, Telp. (031) 8073636 - 39, Fax: (031) 8074269