



# Certificate of Calibration

## Pressure Switch Measurement

Certificate No. : 0082-23-HI-CAL-10B

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-23-0008-OTH

### Instrument Information

KKS No.	50MAX30CP303	Range	15 - 150
Instrument Description	EHC OIL PRESSURE LOW LOW 2	Set	114
Manufacture	NAGANO KEIKI	Reset	120
Model	CB33-2X3	Unit	barg
Serial Number	W1749	MPE	± 0.675
Instrument Location	Turbin Lt. 1	Cal. Date	18-05-2023

### Environment Condition

Temperature 29 °C  
Humidity 62 % RH

### Calibration Result

Data Reading (Switch)					
As Found			As Left		
Set	Reset	Deadband	Set	Reset	Deadband
112.520	118.380	5.860	114.040	120.380	6.340
112.520	118.380	5.860	114.040	120.380	6.340
112.520	118.380	5.860	114.040	120.380	6.340

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	43550006	S. 22 022 080	21-02-2022
PRESSURE MODULE P31	4472839	S. 23 004 595	27-03-2023

### Calibration Method

0003/SOP\_BJS/2023  
Procedure of Calibration Pressure Switch

This certificate comprise of 1 page  
Date of issue, 19-05-2023

Customer Signature,

Ayrton Humardani Putradhi

Approved Signature

Arief Gunawan

Calibrated by,

Ryan Franki Risdianto

**PT. HERVITAMA INDONESIA**

ELECTRICAL - INSTRUMENTATION - ENGINEERING

Puri Indah DA - 18 Sidoarjo 61224, Telp. (031) 8073636 - 39, Fax: (031) 8074269