



Report of Inspection

Vibration Sensor

Report No. : 0250-23-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-23-0008-OTH

Instrument Information

KKS No. 50MAY10CY001 Inspection Date 19-05-2023
Instrument Description BEARING NO.1 VIBRATION X
Manufacture SHINKAWA
Model FL-202F08A-M2-00-05-10
Serial Number T9SH5259
Instrument Location Turbin Lt. 3

Environment Condition

Temperature 31 °C
Humidity 61 % RH

Inspection Result

Visual Inspection

Cabel Tightness	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK
Cable Condition	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK
Mounting	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK
Phisical Condition	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK

Healthiness

Good

Measurement

V - Supply	- 25.31
V - Out	- 08.41
Resistance [Ω]	8.8

Remark

Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
TRUE RMS MULTIMETER	160403244	S. 21 011 088	05-10-2021

Inspection Method

0006/SOP_BJS/2023
Procedure of Inspection Vibration

This certificate comprise of 1 page
Date of issue, 20-05-2023

Customer Signature,

Ayrton Humardani Putradhi

HERVITAMA
Approved Signatory,

Arief Gunawan
INDONESIA

Calibrated by,

Abdul Latif

PT. HERVITAMA INDONESIA

ELECTRICAL - INSTRUMENTATION - ENGINEERING

Puri Indah DA - 18 Sidoarjo 61224, Telp. (031) 8073636 - 39, Fax: (031) 8074269