



Report of Inspection Vibration Sensor

Report No. : 0256-23-HI-CAL-10

Customer Information

Company Name	PT. Bhumi Jati Power
Address	PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No.	C-BJP-23-0008-OTH

Instrument Information

KKS No.	50MAY10CY007	Inspection Date	19-05-2023
Instrument Description	BEARING NO.4 VIBRATION X		
Manufacture	SHINKAWA		
Model	FL-202F08A-M2-00-05-10		
Serial Number	T9SH5265		
Instrument Location	Turbin Lt. 3		

Environment Condition

Temperature	31 °C
Humidity	61 % RH

Inspection Result

Visual Inspection

Cabel Tightness	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK
Cable Condition	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK
Mounting	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK
Phisical Condition	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK

Healthiness

Good

Measurement

V - Supply	- 25.27
V - Out	- 09.07
Resistance [Ω]	9.0

Remark

Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
TRUE RMS MULTIMETER	160403244	S. 21 011 088	05-10-2021

Inspection Method

0006/SOP_BJS/2023
Procedure of Inspection Vibration

This certificate comprise of 1 page
Date of issue, 20-05-2023

Customer Signature,

Ayrton Humardani Putradhi

HERVITAMA
Approved Signatory,

Ariel Gunawan

Calibrated by,

Abdul Latif

PT. HERVITAMA INDONESIA

ELECTRICAL - INSTRUMENTATION - ENGINEERING

Puri Indah DA - 18 Sidoarjo 61224, Telp. (031) 8073636 - 39, Fax: (031) 8074269