



# Certificate of Calibration

## Pressure Switch Measurement

Certificate No. : 0088-23-HI-CAL-10B

### Customer Information

Company Name PT. Bhumi Jati Power  
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No. C-BJP-23-0008-OTH

### Instrument Information

KKS No.	50MKF50CP305	Range	0.4 - 4
Instrument Description	STATOR COOLING WATER GENERATOR INLET PRESSURE LOW LOW 3	Set	2.64
Manufacture	NAGANO KEIKI	Reset	2.76
Model	CB33-2X3	Unit	barg
Serial Number	W12180	MPE	± 0.018
Instrument Location	Turbin Lt. 1	Cal. Date	19-05-2023

### Environment Condition

Temperature 29 °C  
 Humidity 62 % RH

### Calibration Result

Data Reading (Switch)					
As Found			As Left		
Set	Reset	Deadband	Set	Reset	Deadband
2.668	2.758	0.090	2.641	2.717	0.076
2.668	2.758	0.090	2.641	2.717	0.076
2.668	2.758	0.090	2.641	2.717	0.076

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR 754	43550006	S. 22 002 080	21-02-2022
PRESSURE MODULE 700P08	14070813	S. 23 004 594	27-03-2023

### Calibration Method

0003/SOP\_BJS/2023  
 Procedure of Calibration Pressure Switch

This certificate comprise of 1 page  
 Date of issue, 20-05-2023

Customer Signature,

Ayrton Humardani Putradhi

Approved Signature

Arief Gunawan

Calibrated by,

Ryan Franki Risdianto

**PT. HERVITAMA INDONESIA**

ELECTRICAL - INSTRUMENTATION - ENGINEERING

Puri Indah DA - 18 Sidoarjo 61224, Telp. (031) 8073636 - 39, Fax: (031) 8074269