



# Certificate of Calibration

## Pressure Switch Measurement

Certificate No. : 0090-23-HI-CAL-10B

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-23-0008-OTH

### Instrument Information

KKS No.	50MKW30CP301	Range	1.5 - 15
Instrument Description	GENERATOR MAIN SEAL OIL PUMP PRESSURE LOW	Set	9.7
Manufacture	NAGANO KEIKI	Reset	10.7
Model	CB33-2X3	Unit	barg
Serial Number	W11695	MPE	± 0.068
Instrument Location	Turbin Lt. 1	Cal. Date	26-05-2023

### Environment Condition

Temperature 29 °C  
Humidity 60 % RH

### Calibration Result

Data Reading (Switch)					
As Found			As Left		
Set	Reset	Deadband	Set	Reset	Deadband
9.777	10.673	0.896	9.756	10.652	0.896
9.777	10.673	0.896	9.749	10.659	0.910
9.777	10.673	0.896	9.749	10.659	0.910

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR 754	43550006	S. 22 002 080	21-02-2022
PRESSURE MODULE 700P08	14070813	S. 23 004 594	27-03-2023

### Calibration Method

0003/SOP\_BJS/2023  
Procedure of Calibration Pressure Switch

This certificate comprise of 1 page  
Date of issue, 27-05-2023

Customer Signature,

Ayrton Humardani Putradhi

Approved Signatory,

**HERVITAMA**  
  
**INDONESIA**

Calibrated by,

Ryan Franki Risdianto

**PT. HERVITAMA INDONESIA**

ELECTRICAL - INSTRUMENTATION - ENGINEERING

Puri Indah DA - 18 Sidoarjo 61224, Telp. (031) 8073636 - 39, Fax: (031) 8074269