



# Certificate of Calibration

## Temperature Sensor Measurement

Certificate No. : 0231-23-HI-CAL-10D

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-23-0008-OTH

### Instrument Information

KKS No.	50PAB11CT005	Range	0 - 80
Instrument Description	CONDENSER WATER BOX B INLET WATER TEMPERATURE	Unit	°C
Manufacture	YAMARI SANGYO	Out. Signal	-
Model	T/C, TERMINAL HEAD TYPE(TYPE-E:Double Element)	Max. Deviation	1.7 °C (JIS)
Serial Number	5378980	Cal. Date	26-05-2023
Instrument Location	Turbin Lt. 1	Temp. Element	Thermocouple Type E

### Environment Condition

Temperature 25.3 °C  
Humidity 53 % RH

### Calibration Result

Data Reading									
As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	40.010	40.600	0.590	Pass					
50	50.000	50.800	0.800	Pass					
60	60.000	61.200	1.200	Pass					
70	70.000	71.200	1.200	Pass					
80	80.010	81.300	1.290	Pass					

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DRYBLOCK ADDITEL 875	660TH190400016	S-22010642	14-07-2022
FIK-754 DOCUMENTING PROCESS CALIBRATOR	3611011	S. 22 011 747	23-11-2022

### Calibration Method

0002/SOP\_BJS/2023  
Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page  
Date of issue, 27-05-2023

Customer Signature,

Ayrton Humardani Putradhi

Approved Signatory,

Arief Gunawan

Calibrated by,

Khabib Mundzirul Umam