

CERTIFICATE OF CALIBRATION TEMPERATURE INDICATOR SWITCH

Certificate No. : 0981-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60BBT11CT002
Instrument Description U6 UAT A HV WDG TEMP
Manufacture QUALITROL
Model / Serial Number - / -
Instrument Location .TRAFO

Range 0 ~ 150
Unit
Out. Signal 4-20 mA
Max. Deviation 4.5
Cal. Date 07-06-2026
Temp. Element

Environment Condition

Temperature 32 °C Humidity 56 % RH

Calibration Result

As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
45	45.000	47.000	2.000	Pass					
60	59.940	57.000	-2.940	Pass					
90	90.000	88.000	-2.000	Pass					
120	120.200	108.000	-12.200	Fail					
150	149.800	148.000	-1.800	Pass					

Visual Inspection (Checklist if OK)

Leak Check ☐ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☐

Data Reading Switch

Protection System	Standard [°C]	Actual [°C]	Result
Fan (55)	55	57	Pass
Fan 1 (65)	65	68	Pass
Alarm (105)	106	108	Pass
Trip (115)	115	115	Pass

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
TRUE RMS Multimeter Fluke 87V	45910296	UAL04843/26	23-04-2026
Dryblock Isotech Fast Cal	311520-1	08130/GQI-Sert/09/25	28-08-2025

Calibration Method

0002/SOP_BJS/2025
Standard Operating Procedure of Calibration Temperature Element, Temperature Transmitter & Temperature Switch

This certificate comprises 2 pages
Date of issue, 06-07-2026

Customer Signature,



Ayrton Humardani Putradhi

Signature,



Idris Hasan Ashari

Calibrated by,



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person