

CERTIFICATE OF CALIBRATION TEMPERATURE INDICATOR SWITCH

Certificate No. : 0984-26-HI-CAL-10

Customer Information

Company Name PT. Bumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. G-BJP-26-0004-OTH

Instrument Information

KKS No. 60BBT12CT001
Instrument Description U6 UAT B OIL TEMP
Manufacture QUALITROL
Model / Serial Number - / -
Instrument Location TRAFO
Range Unit 0 ~ 150 °C
Out. Signal 4 - 20 mA
Max. Deviation 4.5 °C
Cal. Date 08-06-2026
Temp. Element

Environment Condition

Temperature 31 °C Humidity 67% RH

Calibration Result

Data Reading					Data Reading				
As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	39.970	40.000	0.030	Pass					
60	59.90	58.000	-1.900	Pass					
90	90.050	80.000	-10.050	Fail					
120	120.000	116.000	-4.000	Fail					
150	150.000	144.000	-6.000	Fail					

Visual Inspection (Checklist if OK)

Leak Check ☐ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☐

Data Reading Switch

Protection System	Standard [°C]	Actual [°C]	Result
Fan (85)	85	88	Pass
Fan 1 (95)	95	97	Pass
Alarm	-	-	-
Trip	-	-	-

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Dryblock Isotech Fast Cal	311520-1	08130/GQI-Sert/09/25	28-08-2025
TRUE RMS Multimeter Fluke 87V	45910296	UAL/04843/26	23-04-2026

Calibration Method

0002/SOP_BJS/2025

Standard Operating Procedure of Calibration Temperature Element, Temperature Transmitter & Temperature Switch

This certificate comprises 2 pages

Date of Issue, 17-06-2026


Customer Signature,

Approved Signatory,

Calibrated by,


Ayron Humardani Putradhi


Ivan Hasan Ashari
HERVITAMA
INDONESIA


Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person