CERTIFICATE OF CALIBRATION
DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0105-26-HI-CAL-10

Customer Information

Company Name	PT. Bhumi Jati Power
Address	PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No.	C-BJP-26-0004-OTH

Instrument Information

KKS No.	60ETG10CP004	Range	0 ~ 10
Instrument Description	1ST FLD B ASH CONVERYING PRESSURE	Unit	bar
Manufacture	ROSEMOUNT	Out. Signal	4 - 20 mA
Model / Serial Number	- / 7892360	Max. Error	0.5 %
Instrument Location	FLY ASH	Cal. Date	01-06-2026

Environment Condition

Temperature	30.8 °C	Humidity	71 % RH

Calibration Result

Data Reading (Transmitter)												
As Found						As Left						
Input [bar]	Std Output [mA]	Output UUT [mA]	Deviation	Error [%]	Result	Input [bar]	Std Output [mA]	Output UUT [mA]	Deviation	Error [%]	Result
0.001	4.000	4.001	0.001	0.006	Pass						
2.500	8.000	7.999	-0.001	-0.006	Pass						
5.000	12.000	11.999	-0.001	-0.006	Pass						
7.501	16.001	15.998	-0.003	-0.019	Pass						
10.000	20.000	19.994	-0.006	-0.038	Pass						
75.000	16.000	15.995	-0.005	-0.031	Pass						
4.999	11.998	11.995	-0.003	-0.019	Pass						
2.500	8.000	7.998	-0.002	-0.013	Pass						
0.001	4.000	4.001	0.001	0.006	Pass						

Visual Inspection (Checklist if OK)

Leak Check	☑	Tightness Check	☑	Corrosion Check	☑
Accessories Check	☑	Power Supply	☑		

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	56070038	MAL 26031230	06-03-2026
PRESSURE MODULE FLK 750PD27	6087359	02172/GQI-Sert/03/26	09-03-2026

Calibration Method

0001/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages
Date of issue, 05-06-2026

Customer Signature,	Approved Signatory,	Calibrated by,
Erfan Nanda Gifari	Ivan Hasan Ashari	Akhmad Nashoikhuddin

HERVITAMA INDONESIA

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia
This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia
**Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang*
This certificate is valid if it has approved and signed by authorized person