

CERTIFICATE OF CALIBRATION  
DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0107-26-HI-CAL-10

## Customer Information

Company Name PT. Bumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-26-0004-OTH

## Instrument Information

KKS No. 60ETG31CP001  
Instrument Description ECO AREA ASH CONVEYING PRESSURE  
Manufacture ROSEMOUNT  
Model / Serial Number - / 7892355  
Instrument Location BOILER 5TH FLOOR

Range 0 ~ 10  
Unit bar  
Out. Signal 4 - 20 mA  
Max. Error 0.5 %  
Cal. Date 12-06-2026

## Environment Condition

Temperature 29.8 °C Humidity 71 % RH

## Calibration Result

| Data Reading (Transmitter) |            |            |           |       |        |         |            |            |           |       |        |
|----------------------------|------------|------------|-----------|-------|--------|---------|------------|------------|-----------|-------|--------|
| As Found                   |            |            |           |       |        | As Left |            |            |           |       |        |
| Input                      | Std Output | Output UUT | Deviation | Error | Result | Input   | Std Output | Output UUT | Deviation | Error | Result |
| [bar]                      | [mA]       | [mA]       |           | [%]   |        | [bar]   | [mA]       | [mA]       |           | [%]   |        |
| 0.000                      | 4.000      | 4.002      | 0.002     | 0.013 | Pass   |         |            |            |           |       |        |
| 2.503                      | 8.004      | 8.004      | 0.000     | 0.000 | Pass   |         |            |            |           |       |        |
| 5.006                      | 12.009     | 12.010     | 0.001     | 0.006 | Pass   |         |            |            |           |       |        |
| 7.501                      | 16.001     | 16.002     | 0.001     | 0.006 | Pass   |         |            |            |           |       |        |
| 10.004                     | 20.006     | 20.008     | 0.002     | 0.013 | Pass   |         |            |            |           |       |        |
| 7.501                      | 16.001     | 16.002     | 0.001     | 0.006 | Pass   |         |            |            |           |       |        |
| 5.006                      | 12.009     | 12.009     | 0.000     | 0.000 | Pass   |         |            |            |           |       |        |
| 2.503                      | 8.004      | 8.005      | 0.001     | 0.006 | Pass   |         |            |            |           |       |        |
| 0.00                       | 4.000      | 4.001      | 0.001     | 0.006 | Pass   |         |            |            |           |       |        |

## Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒  
Accessories Check ☒ Power Supply ☒

## Standard Reference

| Description                              | Serial Number | Certificate Number | Calibration Date |
|------------------------------------------|---------------|--------------------|------------------|
| DOCUMENTING PROCESS CALIBRATOR FLUKE 754 | 56070038      | MAL 26031230       | 06-03-2026       |
| FLUKE PRESURE MODULE 700P08              | 14070813      | MAL 26031235       | 03-03-2026       |

## Calibration Method

0001/SOP\_BJS/2025  
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages  
Date of issue, 14-06-2026

Customer Signature,

Erfan Nanda Gifari

Approved Signatory,

HERVITAMA

Ivan Hasan Ashari

Calibrated by,

Akhmad Nashoikhuddin

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

