

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0547-24-HI-CAL-10D

Customer Information

Company Name : PT. Bhumi Jati Power
 Address : PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. : C-BJP-24-0013-OTH

Instrument Information

KKS No. : 60HAD30CT001 Range : 0 ~ 500
 Instrument Description : WATER WALL OUTLET FLUID Unit : °C
 TEMPERATURE 1
 Manufacture : YAMARI Out. Signal : 4 - 20 mA
 Model : TM Max. Deviation : 5 °C
 Serial Number : - Cal. Date : 09-05-2024
 Instrument Location : BOILER 10TH FLOOR Temp. Element : Thermocouple Type E

Environment Condition

Temperature : 28.8 °C
 Humidity : 57 % RH

Calibration Result

As Found					Data Reading				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	40.000	40.200	0.200	Pass					
125	125.050	126.000	0.950	Pass					
250	250.030	251.700	1.670	Pass					
375	375.000	376.900	1.900	Pass					
500	500.080	501.700	1.620	Pass					

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	43550006	S. 22 022 080	21-02-2022
DRYBLOCK ADDITEL 875	660TH190400016	S. 23 008 476 /P	03-07-2023

Calibration Method

0002/SOP_BJS/2023
 Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page
 Date of issue, 10-05-2024

Customer Signature,




Ayrton Humardani Putradhi

Approved Signatory,



M. Hidayat Fhriyan

Calibrated by,



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

