

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0548-24-HI-CAL-10D

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60HAD30CT002	Range	0 ~ 500
Instrument Description	WATER WALL OUTLET FLUID TEMPERATURE 2	Unit	°C
Manufacture	YAMARI	Out. Signal	4 - 20 mA
Model	TM	Max. Deviation	5 °C
Serial Number	-	Cal. Date	09-05-2024
Instrument Location	BOILER 10TH FLOOR	Temp. Element	Thermocouple Type E

Environment Condition

Temperature 28.8 °C
 Humidity 57 % RH

Calibration Result

Data Reading				
As Found			As Left	
Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]		
40	40.000	40.200	0.200	Pass
125	125.010	125.900	0.890	Pass
250	250.030	251.600	1.570	Pass
375	375.010	376.800	1.790	Pass
500	500.010	501.500	1.490	Pass

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	43550006	S. 22 022 080	21-02-2022
DRYBLOCK ADDITEL 875	660TH190400016	S. 23 008 476 /P	03-07-2023

Calibration Method

0002/SOP_BJS/2023
 Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page
 Date of issue, 10-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Teung Nur Sifnyan

Calibrated by,



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

