

CERTIFICATE OF CALIBRATION  
DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0108-26-HI-CAL-10

## Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-26-0004-OTH

## Instrument Information

KKS No. 60HAG01CL001  
Instrument Description STORAGE TANK LEVEL 1  
Manufacture YOKOGAWA  
Model / Serial Number EJX110A / 91V5007779217  
Instrument Location BOILER 6TH FLOOR

Range -2120 ~ 59  
Unit mbar  
Out. Signal 4 - 20 mA  
Max. Error 0.5 %  
Cal. Date 07-06-2026

## Environment Condition

Temperature 32 °C Humidity 75 % RH

## Calibration Result

| Data Reading (Transmitter) |            |            |           |       |        |         |            |            |           |       |        |
|----------------------------|------------|------------|-----------|-------|--------|---------|------------|------------|-----------|-------|--------|
| As Found                   |            |            |           |       |        | As Left |            |            |           |       |        |
| Input                      | Std Output | Output UUT | Deviation | Error | Result | Input   | Std Output | Output UUT | Deviation | Error | Result |
| [mbar]                     | [mA]       | [mA]       |           | [%]   |        | [mbar]  | [mA]       | [mA]       |           | [%]   |        |
| -2120.000                  | 4.000      | 4.004      | 0.004     | 0.025 | Pass   |         |            |            |           |       |        |
| -1575.300                  | 8.000      | 8.004      | 0.004     | 0.025 | Pass   |         |            |            |           |       |        |
| -1030.500                  | 12.000     | 12.004     | 0.004     | 0.025 | Pass   |         |            |            |           |       |        |
| -485.800                   | 16.000     | 16.003     | 0.003     | 0.019 | Pass   |         |            |            |           |       |        |
| 59.000                     | 20.000     | 20.003     | 0.003     | 0.019 | Pass   |         |            |            |           |       |        |
| -485.800                   | 16.000     | 16.004     | 0.004     | 0.025 | Pass   |         |            |            |           |       |        |
| -1030.500                  | 12.000     | 12.003     | 0.003     | 0.019 | Pass   |         |            |            |           |       |        |
| -1575.300                  | 8.000      | 8.003      | 0.003     | 0.019 | Pass   |         |            |            |           |       |        |
| -2120.000                  | 4.000      | 4.004      | 0.004     | 0.025 | Pass   |         |            |            |           |       |        |

## Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒  
Accessories Check ☒ Power Supply ☒

## Standard Reference

| Description                              | Serial Number | Certificate Number   | Calibration Date |
|------------------------------------------|---------------|----------------------|------------------|
| DOCUMENTING PROCESS CALIBRATOR FLUKE 754 | 2448033       | 4482/25/EX/10/2025   | 26-09-2025       |
| FLUKE PRESURE MODULE 700P05              | 14270508      | 02837/GQI-Sert/04/26 | 13-04-2026       |

## Calibration Method

0001/SOP\_BJS/2025  
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages  
Date of issue, 10-06-2026

Customer Signature,

Erfan Nanda Gifari

Approved Signatory,

**HERVITAMA**  
  
**INDONESIA**

Calibrated by,

Ryan Franki Risdianto

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person