

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0109-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No.	60HAG01CL002	Range	-2120 ~ 59
Instrument Description	STORAGE TANK LEVEL 2	Unit	mbar
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model / Serial Number	EJX110A / 91V5007879217	Max. Error	0.5 %
Instrument Location	BOILER 6TH FLOOR	Cal. Date	07-06-2026

Environment Condition

Temperature 31 °C Humidity 74 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
-2120.000	4.000	4.005	0.005	0.031	Pass						
-1575.300	8.000	8.005	0.005	0.031	Pass						
-1030.500	12.000	12.004	0.004	0.025	Pass						
-485.800	16.000	16.005	0.005	0.031	Pass						
59.000	20.000	20.004	0.004	0.025	Pass						
-485.800	16.000	16.005	0.005	0.031	Pass						
-1030.500	12.000	12.004	0.004	0.025	Pass						
-1575.300	8.000	8.005	0.005	0.031	Pass						
-2120.000	4.000	4.005	0.005	0.031	Pass						

Visual Inspection (Checklist if OK)

Leak Check ☒	Tightness Check ☒	Corrosion Check ☒
Accessories Check ☒	Power Supply ☒	

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	2448033	4482/25/EX/10/2025	26-09-2025
FLUKE PRESURE MODULE 700P05	14270508	02837/GQI-Sert/04/26	13-04-2026

Calibration Method

0001/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages
Date of issue, 10-06-2026

Customer Signature,



Erfan Nanda Gifari

Approved Signatory,
HERVITAMA



Muhammad Asyari

Calibrated by,



Ryan Franki Risdianto

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia
This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person