

## CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0193-24-HI-CAL-10C

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60HAG01CP003	Range	0 ~ 350
Instrument Description	STORAGE TANK OUTLET PRESSURE 3	Unit	barg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX440A	Max. Error	0.5 %
Serial Number	91V501028	Cal. Date	20-05-2024
Instrument Location	BOILER 9TH FLOOR		

### Environment Condition

Temperature 31.5 °C  
Humidity 65 % RH

### Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
0.00	4.000	4.000	0.000	0.000	Pass						
87.56	8.003	8.004	0.001	0.006	Pass						
175.06	12.003	12.004	0.001	0.006	Pass						
262.55	16.002	16.004	0.002	0.013	Pass						
350.05	20.002	20.003	0.001	0.006	Pass						
350.05	20.002	20.003	0.001	0.006	Pass						
262.55	16.002	16.008	0.006	0.038	Pass						
175.06	12.003	12.005	0.002	0.013	Pass						
87.56	8.003	8.006	0.003	0.019	Pass						
0.00	4.000	3.999	-0.001	-0.006	Pass						

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
PRESSURE MODULE P31	4472839	S. 23 004 595	27-03-2023

### Calibration Method

0001/SOP\_BJS/2023  
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page  
Date of issue, 21-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Appr. Signature,



M. Taufiq Nur Fitriyan  
INDONESIA

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

*This certificate applies only for the item specified above*

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

*It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval*

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

*This certificate is valid if it has approved and signed by authorized person*

