

**CERTIFICATE OF CALIBRATION**  
**PRESSURE TRANSMITTER**  
Certificate No. : 0196-24-HI-CAL-10C

**Customer Information**

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0013-OTH

**Instrument Information**

KKS No.	60HAH03CP003	Range	0 ~ 400
Instrument Description	FINAL SUPERHEATER OUTLET HEADER PRESSURE 3	Unit	barg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX440A	Max. Error	0.5 %
Serial Number	91V507031	Cal. Date	20-05-2024
Instrument Location	BOILER 9TH FLOOR		

**Environment Condition**

Temperature 31.5 °C  
Humidity 65 % RH

**Calibration Result**

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
0.00	4.000	4.000	0.000	0.000	Pass						
100.04	8.002	8.004	0.002	0.012	Pass						
200.02	12.001	12.001	0.000	0.000	Pass						
300.06	16.002	16.005	0.003	0.019	Pass						
400.03	20.001	19.998	-0.003	-0.019	Pass						
400.03	20.001	19.998	-0.003	-0.019	Pass						
300.06	16.002	16.000	-0.002	-0.012	Pass						
200.02	12.001	12.002	0.001	0.006	Pass						
100.04	8.002	8.001	-0.001	-0.006	Pass						
0.00	4.000	3.999	-0.001	-0.006	Pass						

**Standard Reference**

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
PRESSURE MODULE P31	4472839	S. 23 004 595	27-03-2023

**Calibration Method**

0001/SOP\_BJS/2023  
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page  
Date of issue, 21-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur-Fitriyan

INDONESIA

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

*This certificate applies only for the item specified above*

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

*It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval*

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

*This certificate is valid if it has approved and signed by authorized person*

