

CERTIFICATE OF CALIBRATION PRESSURE SWITCH

Certificate No. : 0537-24-HI-CAL-10B

Customer Information

Company Name: PT. Bhumi Jati Power
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No.: C-BJP-24-0013-OTH

Instrument Information

| | | | |
|------------------------|---|-----------|------------|
| KKS No. | 60HAH03CP304 | Range | 0 - 50 |
| Instrument Description | FINAL SUPERHEATER OUTLET HEADER PRESSURE SWITCH 4 | Set | 27.1 |
| Manufacture | HITACHI HIGH - TECH SOLUTIONS | Reset | 26.6 |
| Model | 220VAS-2A ALARM SETTER | Unit | MPa |
| Serial Number | 1116687 | MPE | ± 0.25 |
| Instrument Location | BOILER 9.33TH FLOOR | Cal. Date | 27-05-2024 |

Environment Condition

Temperature: 29.8 °C
 Humidity: 65 % RH

Calibration Result

| Data Reading (Switch) | | | | | |
|-----------------------|--------|----------|---------|-------|----------|
| As Found | | | As Left | | |
| Set | Reset | Deadband | Set | Reset | Deadband |
| 27.117 | 26.793 | 0.324 | | | |
| 27.152 | 26.779 | 0.373 | | | |
| 27.145 | 26.765 | 0.380 | | | |

Standard Reference

| Description | Serial Number | Certificate Number | Calibration Date |
|--|---------------|--------------------|------------------|
| Documenting Process Calibrator Fluke 754 | 3611011 | S. 22 011 747 | 23-09-2023 |
| PRESSURE MODULE P31 | 4472839 | S. 23 004 595 | 27-03-2023 |

Calibration Method

0003/SOP_BJS/2023
 Procedure of Calibration Pressure Switch

This certificate comprise of 1 page
 Date of issue, 28-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

**Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang*

This certificate is valid if it has approved and signed by authorized person

