

## CERTIFICATE OF CALIBRATION PRESSURE SWITCH

Certificate No. : 0538-24-HI-CAL-10B

### Customer Information

Company Name: PT. Bhumi Jati Power  
Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No.: C-BJP-24-0013-OTH

### Instrument Information

|                        |   |           |            |
|------------------------|---|-----------|------------|
| KKS No.                | 60HAH03CP305                                      | Range     | 0 - 50     |
| Instrument Description | FINAL SUPERHEATER OUTLET HEADER PRESSURE SWITCH 5 | Set       | 27.1       |
| Manufacture            | HITACHI HIGH - TECH SOLUTIONS                     | Reset     | 26.6       |
| Model                  | 220VAS-2A ALARM SETTER                            | Unit      | MPa        |
| Serial Number          | 1116688   | MPE       | ± 0.25     |
| Instrument Location    | BOILER 9.33TH FLOOR                               | Cal. Date | 27-05-2024 |

### Environment Condition

Temperature: 29.8 °C  
Humidity: 65 % RH

### Calibration Result

| Data Reading (Switch) |        |          |         |       |          |
|-----------------------|--------|----------|---------|-------|----------|
| As Found              |        |          | As Left |       |          |
| Set                   | Reset  | Deadband | Set     | Reset | Deadband |
| 27.179                | 26.731 | 0.448    |         |       |          |
| 27.131                | 26.724 | 0.407    |         |       |          |
| 27.172                | 26.697 | 0.475    |         |       |          |

### Standard Reference

| Description                              | Serial Number | Certificate Number | Calibration Date |
|--|---------------|--------------------|------------------|
| Documenting Process Calibrator Fluke 754 | 3611011       | S. 22 011 747      | 23-09-2023       |
| PRESSURE MODULE P31                      | 4472839       | S. 23 004 595      | 27-03-2023       |

### Calibration Method

0003/SOP\_BJS/2023  
Procedure of Calibration Pressure Switch

This certificate comprise of 1 page  
Date of issue, 28-05-2024

Customer Signature,




Ayrtan Humardani Putradhi

Approved Signatory,



M. Taufiqul Hidayat

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

*This certificate applies only for the item specified above*

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT. Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

*This certificate is valid if it has approved and signed by authorized person*

