

CERTIFICATE OF CALIBRATION
PRESSURE TRANSMITTER

Certificate No. : 0054-26-HI-CAL-10

Customer Information

Company Name

PT. Bhumi Jati Power

Address

PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah

Contract No.

C-BJP-26-0004-OTH

Instrument Information

KKS No.

60HAH03CP305

Instrument Description

FINAL SUPERHEATER OUTLET HEADER PRESSURE SWITCH 5

Manufacture

HITACHI HIGH - TECH SOLUTIONS

Model / Serial Number

220VAS-2A ALARM SETTER / 1116688

Instrument Location

BOILER 9.3TH FLOOR

Range

0 - 50

Unit

MPa

Out. Signal

4 - 20 mA

Max. Error

0.5 %

Cal. Date

18-06-2026

Environment Condition

Temperature

31.4 °C

Humidity

58 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[MPa]	[mA]	[mA]		[%]		[MPa]	[mA]	[mA]		[%]	
0.000	4.000	4.000	0.000	0.000	Pass						
12.500	8.000	8.006	0.006	0.038	Pass						
25.000	12.000	12.014	0.014	0.088	Pass						
37.501	16.000	16.020	0.020	0.125	Pass						
50.001	20.000	20.030	0.030	0.188	Pass						
37.501	16.000	16.021	0.021	0.131	Pass						
25.000	12.000	12.015	0.015	0.094	Pass						
12.500	8.000	8.006	0.006	0.038	Pass						
0.000	4.000	4.000	0.000	0.000	Pass						

Visual Inspection (Checklist if OK)

Leak Check



Tightness Check



Corrosion Check



Accessories Check



Power Supply



Standard Reference

Description

Serial Number

Certificate Number

Calibration Date

DOCUMENTING PROCESS

56070038

MAL 26031230

06-03-2026

CALIBRATOR FLUKE 754

FLUKE PRESEURE MODULE

4472839

MAL 26031236

03-03-2026

750P31

Calibration Method

0001/SOP_BJS/2025

Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages

Date of issue, 19-06-2026

Customer Signature,

Erfan Nanda Gifan

Approved Signatory,

HERVITAMA
INDONESIA

Ivan Hasan Ashari

Calibrated by,

Akhmad Nashoikhuddin

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

