

## CERTIFICATE OF CALIBRATION PRESSURE SWITCH

Certificate No. : 0539-24-HI-CAL-10B

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60HAH03CP306	Range	0 - 50
Instrument Description	FINAL SUPERHEATER OUTLET HEADER PRESSURE SWITCH 6	Set	27.1
Manufacture	HITACHI HIGH - TECH SOLUTIONS	Reset	26.6
Model	220VAS-2A ALARM SETTER	Unit	MPa
Serial Number	1162392	MPE	± 0.25
Instrument Location	BOILER 9.33TH FLOOR	Cal. Date	27-05-2024

### Environment Condition

Temperature 29.8 °C  
Humidity 65 % RH

### Calibration Result

Data Reading (Switch)					
As Found			As Left		
Set	Reset	Deadband	Set	Reset	Deadband
27.186	26.786	0.400			
27.117	26.800	0.317			
27.165	26.745	0.420			

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
PRESSURE MODULE P31	4472839	S. 23 004 595	27-03-2023

### Calibration Method

0003/SOP\_BJS/2023  
Procedure of Calibration Pressure Switch

This certificate comprise of 1 page  
Date of issue, 28-05-2024

Customer Signature,



Ayrtan Humardani Putradhi

Approved Signatory,



M. Tauliq Nur Fitriyan

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

