

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0198-24-HI-CAL-10C

Customer Information

Company Name: PT. Bhumi Jati Power
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No.: C-BJP-24-0013-OTH

Instrument Information

KKS No.: 60HBK01CP002
 Instrument Description: FURNACE PRESSURE (RIGHT) 2
 Manufacture: YOKOGAWA
 Model: EJX110A
 Serial Number: 91V501686
 Instrument Location: BOILER 9TH FLOOR

Range: -40 ~ 40
 Unit: mbarg
 Out. Signal: 4 - 20 mA
 Max. Error: 0.5 %
 Cal. Date: 16-05-2024

Environment Condition

Temperature: 27.1 °C
 Humidity: 51 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbarg]	[mA]	[mA]		[%]		[mbarg]	[mA]	[mA]		[%]	
-40	4.000	4.005	0.005	0.031	Pass						
-20	8.000	8.006	0.006	0.038	Pass						
0	12.000	11.999	-0.001	-0.006	Pass						
20	16.000	16.002	0.002	0.012	Pass						
40	20.000	20.007	0.007	0.044	Pass						
40	20.000	20.007	0.007	0.044	Pass						
20	16.000	16.003	0.003	0.019	Pass						
0	12.000	11.999	-0.001	-0.006	Pass						
-20	8.000	8.000	0.000	0.000	Pass						
-40	4.000	4.004	0.004	0.025	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Pressure Module Fluke 750PD4	4474073	S. 23 014 461	10-10-2023

Calibration Method

0001/SOP_BJS/2023
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
 Date of issue, 17-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Appr. **HERVITAMA**



M. Fauzi Nur Fitriyan
INDONESIA

Calibrated by,



Faihol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
 This certificate applies only for the item specified above
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
 *Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
 This certificate is valid if it has approved and signed by authorized person

