

REPORT OF INSPECTION CONTROL VALVE

Certificate No. : 0968-24-HI-CAL-10J

Customer Information

Company Name PT. Bumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0014-OTH

Instrument Information

KKS No. 60HBK03AA204 Sensitivity 0.5 %
Instrument Description PARALLEL GAS SUPERHEATER SIDE DAMPER 4 Damping Time 0.5 s
Manufacture IMI CCL Actuator Action ATC
Model DU-120GHR-1003-E-5 Inspection Date 05-06-2024
Serial Number A24344JP-19D
Instrument Location Boiler Lt. 6.5

Environment Condition

Temperature 30 °C Humidity 42 % RH

Traveling Time

Open to Close 18.51 s Close to Open 18.24 s

Stroke Result

As Found				
Test Point	Local	Feedback	DCS	Stroke
[%]	[%]	[mA]	[%]	[deg]
0	0.3	4.060	0.4	0
25	25.9	8.160	26.0	45
50	50.9	12.160	51.0	90
75	76.2	16.200	76.3	135
100	99.9	20.000	100.0	180

As Left				
Test Point	Local	Feedback	DCS	Stroke
[%]	[%]	[mA]	[%]	[deg]
0	0.0	4.000	0.0	0
25	25.0	8.000	25.0	45
50	50.1	12.010	50.1	90
75	75.0	16.000	75.0	135
100	100.0	20.000	75.0	180

Visual Inspection

Leak Check OK Not OK Tightness Check OK Not OK
Corrosion Condition OK Not OK Accessories Check OK Not OK
Air Regulator Check OK Not OK

Remark

Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
STOPWATCH CASIO	J011Q03	S. 23 004 599	27-03-2023
FIK-87-V MULTIMETER	45910296	S. 22 008 273	13-07-2022
LB02 PROCESS CALIBRATOR	SS18-0015	S.22 012 540	07-10-2022

Inspection Method

0007/SOP_BJS/2023
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page
Date of issue, 06-06-2024

Customer Signature,



Ayrtan Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
This certificate applies only for the item specified above
Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
This certificate is valid if it has approved and signed by authorized person

