

REPORT OF INSPECTION MOTORIZED OF VALVE

Certificate No. : 0839-24-HI-CAL-10J

Customer Information

Company Name PT. Bumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0014-OTH

Instrument Information

KKS No.	60HCB01AA205	Power Supply	380 VAC
Instrument Description	SOOTBLOWER SH SIDE PCV INLET VALVE	Stroke	170 mm
Manufacture	AUMA	Inspection Date	08-05-2024
Model	AS00090-2-1-80		
Serial Number	3618MM75570		
Instrument Location	BOILER 10.5TH FLOOR		

Environment Condition

Temperature 29.4 °C
Humidity 46 % RH

Traveling Time

Open to Close 27.49 s
Close to Open 27.54 s

Stroke Result

Command	Local	Stroke	DCS FB
[%]	[%]	[mm]	[%]

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

Visual Inspection

Leak Check	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK	Tightness Check	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK
Corrosion Condition	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK	Accessories Check	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK
Gearbox Condition	<input checked="" type="checkbox"/>	OK	<input type="checkbox"/>	Not OK					

Remark

Grease Refill (Done)

Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
FIK-87-V MULTIMETER	16230349	S. 22 008 274	08-07-2022
STOPWATCH CASIO	J011Q03	S. 23 004 599	27-03-2023

Inspection Method

005 / Service-HI / 2022
Standard Operating Procedure of Control Valve Calibration

This certificate comprise of 1 page
Date of issue, 09-05-2024

Customer Signature,



Ayrtan Humardani Putradhi

Approved Signatory,



M. Taqig Nur Fitriyan

Calibrated by,



Suryo Wicaksono

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

